



QUANT.	ESPECIFICAÇÃO	POT. UNIT.	POT. TOTAL
02	SPLIT 7000 BTU	800W	1600W
0	SPLIT 9000 BTU	900W	0W
02	SPLIT 12000 BTU	1200W	2400W
07	SPLIT 18000 BTU	1800W	12600W
03	SPLIT 24000 BTU	2300W	6900W
04	SPLIT 30000 BTU	3400W	13600W
02	SPLIT 48000 BTU	4900W	9800W
04	SPLIT 60000 BTU	6500W	26000W
POTENCIA TOTAL			72900W

The technical drawing illustrates the installation details for a split-system air conditioning unit. It includes three main views: a side elevation, a front elevation, and a vertical section.

- ELEVATION LATERAL (Left):** Shows the side profile of the indoor unit. Key dimensions include a total height of 200mm, a top section of 100mm, and a bottom section of 100mm. It also indicates a 100mm gap from the ceiling and a 100mm gap from the wall.
- ELEVATION FRONTAL (Middle):** Shows the front view of the indoor unit. It features two vertical pipes labeled "TUBO DE SUCÇÃO" (Suction Tube) and "TUBO DE ALIMENTAÇÃO" (Supply Tube). The unit is mounted on a wall with a 100mm gap from the ceiling and a 100mm gap from the wall. The bottom section is 100mm high.
- CORTE E - E (Right):** A vertical section view showing the internal components. It labels the "TUBO DE SUCÇÃO" (Suction Tube), "TUBO DE ALIMENTAÇÃO" (Supply Tube), "TUBO DE GÁS" (Gas Tube), and "TUBO DE DRENAÇÃO" (Drainage Tube). It also shows the "CABIDEIRO DE SUCÇÃO" (Suction Hanger) and "CABIDEIRO DE ALIMENTAÇÃO" (Supply Hanger). The unit is mounted on a wall with a 100mm gap from the ceiling and a 100mm gap from the wall. The bottom section is 100mm high.

Below the elevation views, there are two detail drawings:

- AMPLIAÇÃO * 1 * (Left):** A detail view of the suction tube connection, showing the "TUBO DE SUCÇÃO" and "TUBO DE ALIMENTAÇÃO" connected to the unit.
- AMPLIAÇÃO * 2 * (Right):** A detail view of the supply tube connection, showing the "TUBO DE ALIMENTAÇÃO" and "TUBO DE GÁS" connected to the unit.

At the bottom of the page, the text reads: "DETALHE TÍPICO PARA INSTALAÇÃO DE UNIDADES EVAPORADORAS" (Typical detail for installation of evaporator units).

ESPAÇO PARA O CREA:		ESPAÇO PARA O CREA:	
ESPAÇO PARA SMT:		ESPAÇO PARA CÁLCULO DE ÁREA:	
		TERRENO	6.000,00 m²
		CONSTRUÇÃO	1.475,26 m²
		PAVIMENTAÇÃO	3.164,88 m²
		COBERTA	1.723,30 m²
[ESPAÇO PARA APROVAÇÃO SMOCS]			
PROPRIETÁRIO: FUNJURIS - FUNDO ESPECIAL DE MODERNIZAÇÃO DO PODER JUDICIÁRIO			
RESPONSÁVEL TÉCNICO:			
PROJETO: GEORGE MAGNO B. PEIXOTO - CREA REG. NACIONAL 020340337-1			
PROJETO DE CLIMATIZAÇÃO			
NOME DO EMPREENDIMENTO:			
FORUM DA COMARCA DE MARACÁ DEODORO			
ENDEREÇO DO EMPREENDIMENTO:			
FORUM DA COMARCA DE MARACÁ SITUADA NA RODOVIA DEVAL LEMOS S/N MARACÁ DE DEDORO - AL.			
DESENHO:			
GEORGE MAGNO TENORIO PEIXOTO			
CLIENTE:			
IDENTIFICAÇÃO DO PROJETO			
PLANTA COBERTA - INSTALAÇÃO CONDENSADORAS E TUBULAÇÕES			
Nº DA FRANCHA:			
REVO	NOME DO ARQUIVO	ESCALA	AR 01/03
PERIODO2012		1:500	
ESTE PROJETO NÃO POSSUI APROVAÇÃO EM TERCEIROS, SEM ORDEM DE EMPLACAMENTO DO AUTOR.			